



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screened Class E / Category 6 Two Connector Channel

Jyh Eng Technology Co., Ltd.
5 Fl., No. 11, Lane 1, Sec. 1, Yung-An South Road
Lujou City, Taipei County, Taiwan 247, R.O.C.

Attestation of Conformity No. 104412

This type of Class E / Category 6 screened two connector channel has been tested by 3P Third Party Testing and complies with the Class E channel requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1, and the Category 6 channel requirements of ANSI/TIA/EIA-568-B.2-1. The Attestation of Conformity is valid for the actually tested channel sample in T568B designation and consisting of the following components:

<i>Cables from Jyh Eng:</i>	<i>Horizontal Cable, Flexible Cable, Qualification Status:</i>	<i>Type SPO46 Type SPT46 Manufacturer Verified</i>
<i>Conn. Hardw. from Jyh Eng:</i>	<i>Wall Outlet, Patch Panel, Qualification Status:</i>	<i>Type JE307-C6 having PCB Marking 307B-C6 22.JEB 2003 Type PPS-C6 having PCB Marking PPS-C6-PCB 2004.JAN.29 Manufacturer Verified</i>
<i>Patch Cord from Jyh Eng:</i>	<i>Patch Cord, Qualification Status:</i>	<i>Type SPT46M4M Manufacturer Verified</i>

Hoersholm, 3 June 2004

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 3 June 2004

Paul Villien

Poul Villien
Coordinating Manager